



Advanced fire protection systems

July 2023

To whom it may concern:

"T" Pulley Situation

In the previous months, several systems have been installed with "T" pulley of Brooks CP3, this "T" pulley is not listed with the WCK system, therefore this component must not be installed with the system anymore.

At the same time, systems that have already been installed with this component and have been tested and approved by the AHJ will be able to remain with the above component.

All the systems that will be installed from today onwards and in which a "T" pulley will be needed, the "T" pulley that will be used will be of LEHAVOT P.N. 93412506 which is listed with the system.


Elan Alchalel
system Engineer